

# Overcoming Challenges in the ZED-2 Reactor Safety Analysis

TRTR Conference

G.B. Wilkin and K.R. Kumar

2010 September 19-24




UNRESTRICTED / ILLIMITÉ

# ZED-2 50<sup>th</sup> Anniversary

- First criticality on 1960 September 7
- 50 years of safe operation achieved two weeks ago
- CNS sponsoring a Technical Workshop on critical facilities and small reactors
  - 2010 November 1-3, Ottawa, Ontario, Canada
  - CNS website: <http://www.cns-snc.ca/events>
  - Still accepting registrations
  - Tour of ZED-2 on November 3 at CRL

# ZED-2 Overview




- Cylindrical vessel in which fuel rods are hung vertically
- Pump  $D_2O$  moderator into vessel to take reactor critical
- Low power, ~200 W maximum
- Primary shutdown mechanism is moderator dump through 3 lines (1.5 ft dia) back to the dump tanks in the basement
- 8 to 12 standby absorber rods also drop but are not credited in the safety case


## ZED-2's Versatility & Variability

- Can accommodate mixed fuel types in a variable number of fuel rods each with or without CANDU-type or ACR-type channels
- Channel coolants can be light or heavy water, or air, and can vary from channel to channel
  - Some CANDU-type channels can be heated
- Lattices can be square or hexagonal with continuously variable lattice pitch
- Other items can also be placed in the core such as
  - Solid neutron absorbers, self-powered and foil-activation neutron flux detectors, and soluble neutron poisons in the heavy water
- Heavy water purity continuously decreases with time

# Defence in Depth



# Indicated versus Actual Core Power



# ACR LEU Fuel Lesson

- Addendum added to the ZED-2 **FSAR** to accommodate LEU fuel for ACR experiments
  - **Final Safety Analysis Report (supports the license)**
- Limits placed on LEU fuel loading, minimum lattice pitch, and maximum reactivity insertion
- Did not include indicated-to-actual power difference
  - When the power difference was assessed, the safety case failed for smallest allowed lattice pitch
  - ZED-2 was shut down by AECL management
  - Errant case “fixed” by reducing safety-case conservatism
  - Operation resumed under a 2<sup>nd</sup> addendum to FSAR
    - Special CNSC permission was required for each core load
- **Clearly a different approach was required to avoid endless revisions to the FSAR for new experiments**


# Summary of Reasons for FSAR Upgrade

- Last major rewrite of FSAR in 1985
- Include and quantify safety margins
- Explicitly include impact of the difference between indicated and actual core power
- Include uncertainty analysis
- **Challenge: to select an appropriate set of controlled parameters that provides a robust safety case without compromising the facility's versatility while at the same time avoiding endless revisions to the FSAR**
- Many other upgrades performed at the same time
  - This presentation is confined to the safety analysis



# Reference Accident Transient (Design Basis Accident - DBA)

- Indicated power is at the trip condition (200 W)
- Core parameters at their LCO limits
  - Limiting Conditions for Safe Operation
- Step reactivity insertion:  
 $\rho = \beta(\text{U235}) + 1 \text{ mk} = 7.984 \text{ mk}$   
(1 mk =  $10^{-3} \text{ k} = 100 \text{ pcm}$ )
- U235 is the only fissioning nuclide
- One dump valve fails to open and absorber rods are not credited
- Acceptance Criteria (dose to staff and fuel temperature) depend on total energy generated
- All other credible LOR accidents are bounded by this transient
- Other fissioning nuclides are bounded by this transient



# Reference Transient and $E_{AC}$ Equations (LCO Parameters)

$$\frac{dn(t)}{dt} = \frac{\rho(t) - \beta_{U235}}{\Lambda} n(t) + \sum_i \lambda_i C_i(t) \quad P(t) = P_A n(t), \quad n(0) = 1$$

$$\rho(t) = \rho_{IN}(t) + \rho_{OUT}(t) \quad \rho_{IN}(t) = \beta_{U235} + 1 \text{ mk, ramp } 0 \rightarrow 0.1 \text{ ms}$$

$$\rho_{OUT}(t) = -LCR \frac{H_{ex}^3}{2} \left[ \frac{1}{(H_{ex} - \Delta h(t'))^2} - \frac{1}{H_{ex}^2} \right] \quad H_{ex} = H_c + D_{ex}$$

$$t' = t - t_{DUMP}$$

$$E = \int P(t) dt \quad E_{AC} = M F_{\Delta H} F_{fluxpeak} \Delta T C_P \quad \Delta T = 100^\circ\text{C} - T_0$$

$$E < E_{AC} \quad \leftarrow \text{Deposited Energy Acceptance Criterion}$$

# LCO Parameters

- Set of 6 parameters were selected as LCOs
  - Based on reactor physics not physical parameters
    - The parameter values vary significantly with core loading and are calculated for each experiment
  - A limit is specified for each parameter
  - Maximum reactivity insertion:
    - $\rho = \beta_{\text{EXPT}} + 1 \text{ mk}$ , limit:  $\rho \leq \beta_{\text{U235}} + 1 \text{ mk}$
    - Safety case using U235 bounds other fissionable nuclides
  - Other 5 limits are fixed: LCR, fuel mass, critical height, neutron generation time, actual power at trip
    - e.g.,  $P_A < 700 \text{ W}$  at  $P_I = 200 \text{ W}$  to address  $P_A \neq P_I$
  - Limit values are arbitrary but carefully chosen to satisfy the  $E_{AC}$  yet not unduly constrain experiments

# Fixed Parameters

- The remaining parameters have fixed values
  - Not calculated for each experiment
  - Some parameter values are selected to bound experiments with additional margin
  - Some parameters don't depend on the experiment
  - Senior ZED-2 Physicist determines if any fixed parameters must be changed for a given experiment
    - Requires new safety case and CNSC acceptance

# Uncertainty Analysis

- Uncertainty analysis performed on DBA
  - All 6 LCO parameters at the license limits, including  $1\sigma$  standard errors (highly unlikely)
  - Fixed parameters included added margins
- Result was that a 98.8% probability that the deposited energy will not exceed  $E_{AC}$
- Very high probability that  $E_{AC}$  will not be exceeded at license limits

# Quantifying Safety Margins

Case	Margin to $E_{AC}$	Actual Fuel Temp ( $^{\circ}\text{C}$ )
Reference accident transient (at LCO limits)	6.1	56.68
Worst case assessed (ACR/LEU, 24 cm, Gd in $\text{D}_2\text{O}$ )	233	50.07
Errant Addendum case (ACR/LEU, 18 cm)	257	50.06
Typical experiments (CANDU/ACR, NU/LEU, $\text{D}_2\text{O}/\text{H}_2\text{O}$ )	400-1200	50.01-50.04

- Actual fuel  $T$  explicitly calculated during transient
  - Fuel  $T$  safety limit is  $100^{\circ}\text{C}$  (initial fuel  $T$  is  $50^{\circ}\text{C}$ )
- Quantifies the margins in typical experiments between the actual fuel  $T$  and the safety limit

# Summary of New Safety Case

- Establishes Defense in Depth philosophy
  - Introduces operating and safety margins
- Quantifies the very large actual safety margin
- Robust without compromising ZED-2 versatility
  - Can accommodate virtually any core loading without requiring a revision and CNSC approval of the licensing documents
- Addresses all other shortcomings in previous safety case
  - Includes a rigorous uncertainty analysis
  - Explicitly accounts for indicated-actual power discrepancy
  - Evidence provided that the DBA is in fact bounding

**Thank You!**

 **AECL EACL**





# Reference Transient is Bounding (Reactivity Inserted and Rate)

Reactivity Inserted $\beta(\text{U235})=6.984$	Starting Indicated Power (W)	Deposited Energy (kJ)	Time to Trip (s)
7.984 mk, step (reference)	200	412	0
	120	277	0.02
	0.0001	91.9	2.28
2 mk, step (~5%/s period)	200	2.86	0
	120	3.03	1.65
	0.0001	15.3	267
0.495 mk/s (fastest LOR)	120	4.05	4.06
	0.0001	46.3	15.4
0.002 mk/s (slowest LOR)	120	92.1	176
	0.0001	19.9	869

# Reference Transient is Bounding (Fissioning Nuclides)

Kinetics Parameters	Reactivity Limit (mk, step)	Starting Indicated Power (W)	Deposited Energy (kJ)
$\beta(\text{U235})=6.984$	7.984 (reference)	200	412
		120	277
		0.0001	91.9
$\beta(\text{Pu239})=2.28$	3.28	200	39.1
		120	28.9
		0.0001	15.1
$\beta(\text{Nat-U})=7.36$	7.984	200	171
		120	112
		0.0001	25.3

# Reference Transient is Bounding (Actual Power at Trip)

- Actual power at trip (200 W indicated power):

$$P(W) = F7 \times \frac{202.5}{180.9} \times 4.554 \times 10^7 \times \frac{200}{50} \times \frac{1}{F2} \times 1.602 \times 10^{-13}$$

Nuclide	Total MeV/fiss (EPRI-NP-1771)	Prompt MeV/fiss (MCNP F7)	Ratio (±0.001)
<b>U235</b>	<b>202.5</b>	<b>180.9</b>	<b>1.119</b>
Pu239	207.0	189.4	1.093
Pu241	210.7	189.0	1.115
U233	198.0	180.8	1.095
U238	206.0	181.3	1.136
Nat-U	202.7	180.9	1.120

Note: 12.5% (1σ) standard error assigned to *P*

# Prompt Neutron Generation Time

(called  $1/v$  insertion method or  $\alpha$ -static method)

- From static perturbation theory

$$\Lambda = \frac{\left( \Phi^*, \frac{1}{v} \Phi \right)}{\left( \Phi^*, F \Phi \right)} \quad \text{and} \quad \Delta\rho = - \frac{\left( \Phi^*, \Delta M \Phi \right)}{\left( \Phi^*, F \Phi \right)}$$

- Setting  $\Delta M = \Delta\alpha/v$  and solving for  $\Lambda$  yields



$$\Lambda = \lim_{\Delta\alpha \rightarrow 0} \left( - \frac{\Delta\rho}{\Delta\alpha} \right) = - \left( \frac{\partial\rho(\alpha)}{\partial\alpha} \right)_{\alpha=0}$$

- MCNP4C ACODE option is used to calculate several values of  $\rho(\alpha)$  by repeatedly solving  $k$ -eigenvalue equation with  $\alpha$  constant:

$$\frac{1}{k} F \Phi = \left[ M + \frac{\alpha}{v} \right] \Phi$$

# Uncertainty Analysis

- 17 input parameters set at reference values:  $\Lambda$ ,  $\rho_{IN}$ ,  $P_A$ ,  $LCR$ ,  $H_C$ ,  $(\beta_i, \lambda_i, i=1,6)$ , each with a  $1\sigma$  uncertainty
  - Uncertainty in  $M$  is included in the  $E_{AC}$
  - Remaining parameters at their fixed values
- Repeatedly solve transient randomly sampling all 17 distributions each time
- Produces a log-normal distribution
  - linear normal probability plot of  $\ln(E)$ ,  $R=0.9983$
- 98.8% of the  $\ln(E)$  distribution is less than  $\ln(E_{AC})$
- Very high confidence that  $E_{AC}$  will not be exceeded in the DBA with all parameters at their LCO limits or fixed values, including uncertainties and margins



# Fixed Parameters

$$\frac{dn(t)}{dt} = \frac{\rho(t) - \beta_{U235}}{\Lambda} n(t) + \sum_i \lambda_i C_i(t) \quad P(t) = P_A n(t), \quad n(0) = 1$$

$$\rho(t) = \rho_{IN}(t) + \rho_{OUT}(t) \quad \rho_{IN}(t) = \beta_{U235} + 1 \text{ mk, ramp } 0 \rightarrow 0.1 \text{ ms}$$

$$\rho_{OUT}(t) = -LCR \frac{H_{ex}^3}{2} \left[ \frac{1}{(H_{ex} - \Delta h(t'))^2} - \frac{1}{H_{ex}^2} \right]$$

$$H_{ex} = H_c + D_{ex}$$

$$t' = t - t_{DUMP}$$

$$E = \int P(t) dt$$

$$E_{AC} = M F_{\Delta H} F_{fluxpeak} \Delta T C_P$$

$$\Delta T = 100^\circ\text{C} - T_0$$

$$E < E_{AC}$$